

[Return to search](#)[Print Page](#)

Product Number: 21777

Order Abbreviation: FO32/830/ECO

General Description: 32W, 48" MOL, T8 OCTRON fluorescent lamp, 3000K color temperature, rare earth phosphor, 85 CRI, suitable for IS or RS operation, ECOLOGIC

Product Information

Abbrev. With Packaging Info.	FO32830ECO 30/CS 1/SKU
Actual Length (in)	47.78
Actual Length (mm)	1213.6
Bulb	T8
Diameter (in)	1.10
Diameter (mm)	27.9
Family Brand Name	Octron® 800, Ecologic
Industry Standards	ANSI C78.81 - 2001
Mean Lumens at 25C	2802
Nominal Length (in)	48

Additional Product Information

Product Documents, Graphs, and Images

Compatible Ballast

Packaging Information



Footnotes

- The life rating of FO32/800/ECO OCTRON® lamps operated on rapid start ballasts is 30,000 hours. The life rating of FO32/800/ECO OCTRON lamps operated on instant start ballasts is 24,000 hours.
- Approximate initial lumens after 100 hours operation.
- The life ratings of fluorescent lamps are based on 3 hr. burning cycles under specified conditions and with ballast meeting ANSI specifications. If burning cycle is increased, there will be a corresponding increase in the average hours life.
- Minimum starting temperature is a function of the ballast; consult the ballast

manufacturer.

- OCTRON lamps should be operated only with magnetic rapid start ballasts designed to operate 265 mA, T-8 lamps or high frequency (electronic) ballasts that are either instant start, or rapid start, or programmed rapid start specifically designed to operate T8 lamps. OCTRON lamps may be operated on instant start ballasts with ballast factors ranging from a minimum of 0.71 to a maximum of 1.20 at the nominal ballast input voltage. When OCTRON lamps are operated in the instant start mode, the two wires or two contacts of each socket should be connected to each other. They should then be connected to the appropriate ballast lead wire using National Electric Code techniques.
- SYLVANIA ECOLOGIC fluorescent lamps are designed to pass the Federal Toxic Characteristic Leaching Procedure (TCLP) criteria for classification as non-hazardous waste in most states. TCLP test results are available upon request. Lamp disposal regulations may vary, check your local & state regulations. For more information, please visit www.lamprecycle.org
- The lamp lumen maintenance factor used to determine the mean lumen value was 95%. This is the lamp lumen maintenance factor at 8000 hours, 40% of 20,000 hours. It was used for comparison to standard OCTRON(R) lamps with an average rated life of 20,000 hours. The lamp lumen maintenance factor at 40% of 24,000 hours, 9600 hours, would be 94%. The lamp lumen maintenance factor at 40% of 30,000 hours, 12,000 hours, would be 93%. The lamp lumen maintenance factor at 40% of 36,000 hours, 14,400 hours would also be 93%.

[Print Page](#)