

Specifications

| | | | |
|----------------------|-----------|--------------------------|--|
| List UOM Qty | 1 | Order UOM | ft |
| Brand Name | HWC | Environmental Conditions | IEEE 383 (70000 BTU/Hour) 00 BTU/Hour) Flame Test |
| Strands | 7 | Insulation Thickness | 15 mil |
| Jacket Material | PVC | Jacket Thickness | 45 |
| Number of Conductors | 4 | Outside Diameter | 0.38 |
| Stranded/Solid | Stranded | Temperature Rating | 90 deg C Dry/Wet |
| Insulation Material | PVC/Nylon | Voltage Rating | 600 Volt |
| Manufacturer Name | HWC | Manufacturer Part Number | HW15101404 |
| Conductor Material | Copper | Item Name | Control Tray Cable |
| RoHS Flag | Yes | UNSPSC | 41113630 |

Standards

UL Listed, UL Type TC Per Article 336 of the NEC, NEC Class I and II, Division 2 Hazardous Locations, Article 725 of the NEC, TC-ER Rated

Energy Star Flag

No

Country Of Origin

France

Wire Gauge Size

14 AWG