

TECHNICAL DATA

Fluke 373 True-RMS AC Clamp Meter





Key features

- A top performing True-RMS current clamp for AC-only current measurements to 600 A
- Measures AC and DC voltage to 600 V
- Measures resistance to $6000 \ \Omega$ with continuity detection
- Offers state of the art signal processing to provide stable readings even in noisy electrical environments

Product overview: Fluke 373 True-RMS AC Clamp Meter

Fluke 373 True RMS AC Clamp Meter does the job for any AC-only current measurement application

Fluke 373 True-RMS AC Clamp Meter is a great choice for AC-only current measurement situations. Featuring True RMS AC voltage and current measurements you can measure AC current to 600 A and AC voltage to 600V. The 373 also measures DC voltage to 600 V and resistance to 6000Ω .

To make it even easier to use, the large, easy-to-read backlit display provides better visibility in dimly lit conditions. And the 373 automatically sets the correct measurement range based on the voltage present when you power up, so you do not need to move the switch while taking a measurement. When you put it all together, you'll find the Fluke 373 offers everything you need, plus a little more.

Other useful capabilities:

- Provides True-RMS voltage and current measurements to accurately measure non-linear signals
- Automatically selects a measurement range based on voltage present so you don't need to change the switch positions



while taking a measurement

- Presents readings on a large, easy-to-read backlit display
- Features CAT IV 300 V, CAT III 600 V safety ratings
- Comes with a soft carrying case and three-year warranty
- Runs on two AA alkaline batteries

Specifications: Fluke 373 True-RMS AC Clamp Meter

| Electrical Specifications | | |
|------------------------------|-------------------------------|--|
| AC Current | | |
| Range | 600.0 A | |
| Resolution | 0.1 A | |
| Accuracy | 2 % ± 5 digits (48 – 62 Hz) | |
| Crest Factor (50/60 Hz) | 2.5 @ 600 A | |
| AC Voltage | | |
| Range | 600.0 V | |
| Resolution | 0.1 V | |
| Accuracy | 1.0 % ± 5 digits (48 – 62 Hz) | |
| DC Voltage | | |
| Range | 600.0 V | |
| Resolution | 0.1 V | |
| Accuracy | 1 % ± 5 digits | |
| Resistance | | |
| Range | 600.0 Ω/6000 Ω | |
| Resolution | 0.1 Ω/1 Ω | |
| Accuracy | 1 % ± 5 digits | |
| Continuity Beeper | 30 Ω | |
| Capacitance | | |
| Range | 10.0 – 100.0 μF / 1000 μF | |
| Resolution | 0.1 μF/1 μF | |
| Accuracy | 1.9 % ± 2 digits | |
| Mechanical Specifications | | |
| Size (L x W x H) | 232 mm x 85 mm x 45 mm | |
| Weight | 370 g | |
| Environmental Specifications | | |
| Operating Temperature | -10 °C to +50 °C | |
| Storage Temp | -40 °C to +60 °C | |



| Operating Humidity | Non condensing (< 10 °C) ≤ 90 % RH (at 10 °C to 30 °C) ≤ 75 % RH (at 30 °C to 40 °C) ≤ 45 % RH (at 40 °C to 50 °C) (Without Condensation) |
|--------------------------|--|
| Operating Altitude | 3000 meters |
| Storage Altitude | 12,000 meters |
| EMI, EMC | Meets all applicable requirements in EN61326-1:2006 |
| Temperature Coefficients | Add 0.1 x specified accuracy for each degree C above 28 $^{\circ}\mathrm{C}$ or below 18 $^{\circ}\mathrm{C}$ |
| Safety Compliance | ANSI/ISA S82.02.01:2004 CAN/CSA-C22.2 No. 61010-1-04 IEC/EN 61010-1:2001, 600V CAT III, 300V CAT IV Pollution Degree 2 EN/IEC 61010-2-32:2002 EN/IEC 61010-031:2002/A1:2008 |
| Agency Approvals | |
| Batteries | 2 AA, NEDA 15A, IEC LR6 |



Ordering information



Fluke 373

Fluke 373 True RMS AC Clamp Meter

Includes:

- Coated instruction card
- Safety information sheet
- Soft carrying case
- TL75 test leads
- Five AA Alkaline batteries

R-FLUKE-373

Fluke 373 True-RMS AC Clamp Meter, fully reconditioned to original factory specifications. Includes Fluke's 3 year product warranty.



Fluke. Keeping your world up and running.®

Fluke Corporation PO Box 9090, Everett, WA 98206 U.S.A.

For more information call:

In the U.S.A. (800) 443-5853 In Canada (800) 36-FLUKE From other countries +1 (425) 446-5500 www.fluke.com ©2023 Fluke Corporation. Specifications subject to change without notice. 03/2023

Modification of this document is not permitted without written permission from Fluke Corporation.